22-42	A. Identification a	2. Da	te: Octo	ber 1, 200)3	7. Pre PDF Pg.No.: 8. Req. Adeq. Pub. Fac.								
	1. Project Number Agency Number		Update Code		Double	Revised:								
	894832	W-73.12	Revis											
	B. Project Name: Potomac WFP Hydropneumatic Surge Tanks and Backwash System Impr 5.Agency: WSSC													
	4. Program: Sanitation 6. Planning Area:				Bi-Co	Bi-County								
	B. Expenditure Schedule (000's)													
			(8)	(9)	(10)	(11)	(12)	(13)	(14)	(15)	(16)	(17)	(18) Beyond	
	Cost Elements		Total	Thru FY '03	Estimate FY '04	Total 6 Years	Year 1 FY '05	Year 2 FY '06	Year 3 FY '07	Year 4 FY '08	Year 5 FY '09	Year 6 FY '10	6 Years	

В.		•			,000	~ <i>,</i>					
	(8) Total	(9) Thru FY '03	(10) Estimate FY '04	(11) Total 6 Years	(12) Year 1 FY '05	(13) Year 2 FY '06	(14) Year 3 FY '07	(15) Year 4 FY '08	(16) Year 5 FY '09	(17) Year 6 FY '10	(18) Beyond 6 Years
Cost Elements Planning, Design & Supervision		1,097	383	295	185	110	1107	11.00	11.00	-:	202
Planning, Design & Supervision	1,977	1,097	363	293	100	110			ļ		
Land											
Site Improvements & Utilities											
Construction	7,325			4,961	2,774	2,187					2,364
Other	1,231		57	789	444	345					385
Total	10,533	1,097	440	6,045	3,403	2,642					2,951
			Frankline	Cabadii	- (000'-)						

C. Funding Schedule (000's)											
WSSC Bonds	10,533	1,097	440	6,045	3,403	2,642					2,951

D. Description & Justification

DESCRIPTION

This project provides for the design and construction of hydropneumatic surge tanks at the Potomac Water Filtration Plant to protect the water distribution system from high and low pressure extremes that result from surge events created by pump trips (power shut-off) at the Plant. Two spherical tanks (estimated 43'-6" diameter) are needed to serve the Prince George's and Montgomery County Main Zones. This project also includes a 36-inch diameter connection from the main zone piping to the filter backwash system, as recommended by the Potomac WFP Reliability Study.

Service Area Montgomery High Pressure Zone HG660, Montgomery Main Pressure Zone HG495, Prince George's Main Pressure Zone HG320

JUSTIFICATION

Plans & Studies

Project 80 Main Zone Surge Study, Boyle Engineering, Inc.; Hydropneumatic Storage Facility Evaluation (1990); Dr. C. Samuel Martin's - Evaluation of Surge Protection Needs (1992); Phase I Report: Network and Demand Improvements Surge Analysis (1994); Phase II Report: Calibration Scenario Development and Modeling (1994); Letter Reports I, II and III (1995); Potomac WFP Facility Plan (September, 2002).

Specific Data

Adverse pressure and vacuum conditions, resulting from surge, have been documented which include low pressure at the National Institute of Standards & Technology and the recurring problem of vacuum severe enough to disrupt service to the Potomac Manor Subdivision. Contamination of the water distribution system is possible when vacuum conditions occur. As water demands increase over time, a larger segment of the water distribution system will be impacted by vacuum conditions resulting from pump trips and the vacuum conditions experienced will be of greater severity. The hydropneumatic surge tanks will reduce the pressure variations caused by pump trips. Monitoring of pressures will be performed for a year after the surge tanks have been installed to determine if additional measures are needed to eliminate occurrences of vacuum conditions. Costs beyond six years are for surge tanks for the Montgomery High Zone, HG 660, if needed. The backwash system improvements involves increasing the size of the connection to the main zone piping from 24-inch to 36-inch diameter. Both the surge tanks and backwash system will share the new connection to the existing 78-inch diameter main piping.

Cost Change

Total project cost increased due to the change in scope.

STATUS Preliminary Design (WSSC Contract No. BF7592A88,).

OTHER

The project scope has changed to include backwash system improvements. An independent third party analysis of the surge modeling

E. Annual Opera	iting Budget Impact (00	0's)	FY of Impact
Program Costs	Staff		
, regram cons	Other		
Facility Costs	Maintenance	76	
·	Debt Service	743	
Total Costs			
Impact on Water	or Sewer Rate	2¢	

F. Approval and Expenditure Data (000's) FY 89 Date First in Capital Program FY 89 Date First Approved 6.581 Initial Cost Estimate Cost Estimate Last FY 9.414 10,533 **Present Cost Estimate** 2,470 Approved Request, Last FY Total Expenditures & Encumbrances 1,097 Approval Request FY 05 3,403 Supplemental Approval Request

G. Status Information

Land Status:

Current FY (04)

No land or R/W involved

% Project Completion: Est. Completion Date:

D-15% FY 2006

H. Map Map Reference Code:

MAP NOT AVAILABLE

D. DESCRIPTION & JUSTIFICATION (CONT.) Agency Number: W - 73.12 Project Name: Potomac WFP Hydropneumatic Surge Tanks and Backwash System Impro	vements
and of the alternatives considered to reduce surge has been completed. Expenditures shown in Block B are planning level estimates only and may increase or decrease. Upon completion of preliminary design, a more reliable estimate can be made.	
COORDINATION	
National Park Service.	
NOTE This project supports 100% System Improvement.	